



# Marinette Fire Department

Chief Jay Heckel

## VENDOR TENT REQUIREMENTS

All vendors utilizing tents shall observe the hi-lighted portions of NFPA 102 Chapter 8 and NFPA 701 Chapter 15. Tents shall be labeled as meeting required flame propagation performance requirements in these chapters. Labeling is also required on each attachable side wall or tarp for tents. These labeling requirements do not apply to canopies of <400 square feet (20'x20').

Please carefully observe the tent spacing requirement of **10 feet between stake lines** set forth in these codes.

Portable extinguishers shall be a minimum of 2A 10BC which is required by M.M.C. 5.0228. Extinguishers shall be up to date and accessible at all times. For deep frying operations a class "K" extinguisher may **also** be present.

**NO SMOKING** signs shall be conspicuously posted in all tents. It is up to the vendor to enforce NO Smoking.

These code requirements are for the safety of all involved and are not meant to create a burden or hardship for anyone. The Marinette Fire Department respectfully requests your compliance with these codes to ensure a **SAFE** and **ENJOYABLE** event for everyone. If there are any questions please contact us at 715-732-5178.

Thank you,

A handwritten signature in blue ink that reads "Jay Heckel". The signature is fluid and cursive.

Chief Jay Heckel