

Finished Drinking Water - PFAS 533 (ng/L)

	PFOA	PFOS	PFHxA	PFHpA	PFNA	PFHxS	PFBS	GenX	6:2 FTSA	PFPeA	PFBA
10/14/2022	Non-Detectable	Non-Detectable	9	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	63	7	3
10/15/2022	Non-Detectable	Non-Detectable	7	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	44	6	3
10-16--2022	Non-Detectable	Non-Detectable	7	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	41	6	3
10/17/2022	Non-Detectable	Non-Detectable	6	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	25	7	3
Min	0	0	6	0	0	0	0	0	25	6	3
Max	0	0	9	0	0	0	0	0	63	7	3
Average	#DIV/0!	#DIV/0!	7.25	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	43.25	6.5	3

Note: Previous Samples for PFAS analyzed by EPA 537.1 did not test for 6:2 FTSA, PFPeA, or PFBA. There is no historical data for these compounds in City of Marinette's drinking water treatment system.

Note (2): Merit Labs has set a reporting limit of 2.0 ng/L. Data for results found below 2.0 ng/L is reported as Non-Detectable by the lab.

Note: All results are in ng/L (parts per trillion)