

Finished Drinking Water - PFAS 533 (ng/L)											
	PFOA	PFOS	PFHxA	PFHpA	PFNA	PFHxS	PFBS	GenX	6:2 FTSA	PFPeA	PFBA
10/11/2022	Non-Detectable	Non-Detectable	9.24	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	712	8.76	Non-Detectable
10/12/2022	Non-Detectable	Non-Detectable	25.5	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	437	9.88	Non-Detectable
10/13/2022	Non-Detectable	Non-Detectable	8.47	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	127	6.06	Non-Detectable
10/14/2022	Non-Detectable	Non-Detectable	9	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	63	7	3
10/15/2022	Non-Detectable	Non-Detectable	7	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	44	6	3
10-16--2022	Non-Detectable	Non-Detectable	7	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	41	6	3
10/17/2022	Non-Detectable	Non-Detectable	6	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	25	7	3
10/18/2022	Non-Detectable	Non-Detectable	3	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	15	4	3
10/19/2022	Non-Detectable	Non-Detectable	6	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	20	4	2
10/20/2022	Non-Detectable	Non-Detectable	7	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	23	4	2
10/21/2022	Non-Detectable	Non-Detectable	7	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	21	5	3
10/22/2022	Non-Detectable	Non-Detectable	4	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	15	3	2
10/23/2022	Non-Detectable	Non-Detectable	4	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	15	3	2
10/24/2022	Non-Detectable	Non-Detectable	4	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	14	4	3
10/25/2022	Non-Detectable	Non-Detectable	3	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	10	3	2
10/26/2022	Non-Detectable	Non-Detectable	3	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	10	3	3
10/27/2022	Non-Detectable	Non-Detectable	3	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	7	3	2
10/28/2022	Non-Detectable	Non-Detectable	2	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	3	2	2
10/31/2022	Non-Detectable	Non-Detectable	2	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	Non-Detectable	5	2	2
11/3/2022	Non-Detectable	5	2	2							
11/7/2022	Non-Detectable	4	2	3							
11/10/2022	Non-Detectable	5	Non-Detectable	2							
Min	0	0	2	0	0	0	0	0	3	2	2
Max	0	0	25.5	0	0	0	0	0	712	9.88	3
Average	#DIV/0!	#DIV/0!	6.33	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	73.68181818	4.50952381	2.473684211

Note: Previous Samples for PFAS analyzed by EPA 537.1 did not test for 6:2 FTSA, PFPeA, or PFBA. There is no historical data for these compounds in City of Marinette's drinking water treatment system.

Note (2): Merit Labs has set a reporting limit of 2.0 ng/L. Data for results found below 2.0 ng/L is reported as Non-Detectable by the lab.

Note: All results are in ng/L (parts per trillion)