

## 2023 Quarterly PFAS Sampling

Sample Location	Sample Date	PFOA (ppt)	PFOS (ppt)	PFHxA (ppt)	PFHpA (ppt)
		LOD=0.47	LOD=0.30	LOD=0.45	LOD=0.42
		LOQ=1.5	LOQ=0.96	LOQ=1.5	LOQ=1.4
EP-81 (Finished Drinking Water)	2/13/2023	[1.10]	[0.59]	[1.40]	[0.68]

LOD= Limit of Detection: As low as the instrument can detect.

LOQ= Limit of Quantitation: As low as the instrument can detect with 100% certainty.

ppt = parts per trillion or nanograms per liter (ng/L)

Non-Detectable = Substance was not found above laboratory limit of detection

[ ] = Substance was found between laboratory limit of detection and limit of quantification