

## 2023 Quarterly PFAS Sampling

Sample Location	Sample Date	PFOA (ppt)	PFOS (ppt)	PFHxA (ppt)	PFHpA (ppt)
		LOD=0.47	LOD=0.30	LOD=0.45	LOD=0.42
		LOQ=1.5	LOQ=0.96	LOQ=1.5	LOQ=1.4
EP-81 (Finished Drinking Water)	2/13/2023	[1.10]	[0.59]	[1.40]	[0.68]

Sample Location	Sample Date	PFOA (ppt)	PFOS (ppt)	PFHxA (ppt)	PFHpA (ppt)	PFHxS (ppt)	PFBS (ppt)
		LOD=0.49	LOD=0.31	LOD=0.47	LOD=0.44	LOD=0.34	LOD=0.30
		LOQ=1.6	LOQ=1.0	LOQ=1.6	LOQ=1.5	LOQ=1.1	LOQ=1.0
EP-81 (Finished Drinking Water)	5/17/2023	[1.40]	1.1	[1.60]	[0.94]	[0.40]	[0.39]

Sample Location	Sample Date	PFOA (ppt)	PFOS (ppt)	PFHxA (ppt)	PFHpA (ppt)	PFHxS (ppt)	PFBS (ppt)
		LOD=0.51	LOD=0.32	LOD=0.49	LOD=0.46	LOD=0.35	LOD=0.31
		LOQ=1.7	LOQ=1.0	LOQ=1.7	LOQ=1.6	LOQ=1.1	LOQ=1.0
EP-81 (Finished Drinking Water)	8/23/2023	[1.3]	[0.97]	[1.5]	[0.88]	[0.37]	[0.34]

Sample Location	Sample Date	PFOA (ppt)	PFOS (ppt)	PFHxA (ppt)	PFHpA (ppt)	PFHxS (ppt)	PFBS (ppt)
		LOD=0.49	LOD=0.31	LOD=0.47	LOD=0.44	LOD=0.34	LOD=0.30
		LOQ=1.6	LOQ=1.0	LOQ=1.6	LOQ=1.5	LOQ=1.1	LOQ=1.0
EP-81 (Finished Drinking Water)	12/13/2023	[1.1]	[0.90]	[1.20]	[0.88]	[0.38]	Non-Detectable

LOD= Limit of Detection: As low as the instrument can detect.

LOQ= Limit of Quantitation: As low as the instrument can detect with 100% certainty.

ppt = parts per trillion or nanograms per liter (ng/L)

Non-Detectable = Substance was not found above laboratory limit of detection

[ ] = Substance was found between laboratory limit of detection and limit of quantification